कार्यालय नगर पंचायत पारशिवनी
पोलीसस्टेशनजवळ,
पारशिवनी,जिल्हा:-नागपूर ४४११०५

जा.क्र...4345.....न.पं.पा./न.र.वि./२०२६

दिनांक :-15/9/२०२६

# Final Fire Safety Approval

**To.**

**SAROJANI PUBLIC SCHOOL,**
**Kh.No. 418, Mouza. Parseoni,**
**Tah. Parseoni, Dist. Nagpur.**

**Subject :- Regarding Final Fire Safety Approval for commercial building Type-II of SAROJANI PUBLIC SCHOOL, Kh.No. 418, Old Dighalwadi road, Parseoni Tah. Parseoni, Dist. Nagpur.**

**Ref. :-** 1) Provisional Certificate From Directorate of Maharashtra Fire Service (Fire & Emergency Service Dept) vide Noc. No. MFS/51/2025/427, Dated. 14/09/2025.
2) Application from Owner/Occupler for request for approval on final compliance/NOC for Sarojani Public School,
Nagar Panchayat CFC Inward No.127831, Dated. 14/07/2026,
CFO/FES/NPP/ Inward No. 859, Dated. 15/07/2026.

With reference to above mentioned subject the First NO-objection (Provisional Fire Safety Approval) certificate No. MFS/51/2025/427, Dated. 14/09/2025. was issued by Director Maharashtra Fire Service in respect of adequate and effective FIRE stallation of Fire safety measures in the Commercial building Type-1 & Type-II (Ground 3rd floor) and having address of. Kh.No. 418, Old Dighalwadi road,Parseoni Tah. Parseoni, Dist. Nagpur.

Now Application from Sarojani Public School for the Final Fire Safety Approval for Type-II, Commercial building (Ground 3rd Floored R.C.C. structured) and Kh.No. 418, Old Dighalwadi road,Parseoni Tah. Parseoni, Dist. Nagpur.

This Final Fire safety approval is issued on the basis of undertaking Submitted by owner.

**With application Applicant has submitted following Documents.**

1) Letter from Sarojani Public School.
2) Form "A" From M/s. Trishiv Infra Solutions, Fire Safety Services License No. MFS-LA/RF-454, MFS- LA/RD-409, with Annexure.
3) Electrical Certificate.
4) Structure Stability Certificate.
5) Nagar Panchayat Tax Copy.
6) Sanction plan with Building Permit.

7) Provisional Fire Safety NOC Certificate.
8) Site Hard Photo Copies.
9) Certificate of architect for overhead & Underground tank capacity.
10) Undertaking form.
11) Form "N" from Maharashtra Fire License Holder M/s. Trishiv Infra Solutions, Fire Safety Services License No. MFS-LA/RF454, MFSLA/RD9, with Annexure, for execution/ maintenance of Fire Fighting system.

Fire Officer, Nagar Parishad Parseoni visited the site & found that the Fire Fighting System is in good working condition, there.

Hence there is no objection to issue Final Fire Safety Approval for the Commercial Building Type II (Ground + 3rd Floored R.C.C. structured) Kh.No. 418, Old Dighalwadi road, Parseoni Tah. Parseoni, Dist. Nagpur.

**Terms &conditions:-**

1) Final Fire safety approval is granted for one year only.
2) Final Fire safety approval to be renew every year.
3) Open space should be kept free of obstructions around the building.
4) All staff and guards should be trained to operate and handling fire fighting equipment's.
5) Emergency Plan should be prepared.
6) For Fire Fighting rescue & evacuation mock drill carried out once in a 3 months
7) Applicant should properly maintain all fire fighting, fire protection, prevention & safety equipment installation regularly.
8) Fire and Emergency Services reserve the right to amend/change condition or impose new conditions considering the safety requirements of life, property, budding. & surroundings
9) The condition of the certificate shall be binding not only the applicant but also its sucessors and every persons deriving title through or under him.
10) Every year there will be inspection by Fire & Emergency Service, Nagar Panchayat.
11) During the occupancy of the building if anything happens due to non compliance the fire protection, fire prevention & safety equipment installation as stated in the certificate. The entire responsibility lies with occupier/owner/developer and its other professional responsible building development. In no case, Nagar Panchayat shall be held responsible for any lapse of whatever reason by occupier/owner/developer& its other professionals.
12) Storage of water for fire fighting purpose shall always be available with alternative Source of supply.
13) Every six month the applicant have to inform in written regarding all fire fighting, fire protection, fire prevention, safety arraignments and equipment are in working conditions to fire officer.
14) Form B from licence agency should be submitted at the time of renewal or January & July.
15) At the time of inspection if the fire fighting& safety installation not found in working condition. as stated in Provisional fire Approval/ First No Objection Certificate. The Final Fire Safety Approval will be cancelled without pre intimation.

16) These Final Fire Safety Approval is issued from fire risk point of view only, without prejudice to legal matters pending in the court of law, other permissions by concerned authorities, Environment Authority, etc. as per rules applicable, are obtained from concerned departments/authority.

17) The remarks are offered for installation of Fire Protection System only, the authenticity of land, building structure, road, open space shall be checked by building department and concerned authorities.

18) As per Maharashtra fire prevention and life safety measures Act, 2006, Section 25-Annexure-Part-III, Sarojani Public School has paid fire Protection Fund Fees amounting to Maharashtra Fire Service Academy Mumbai Rs. 1,71,065/- (Rs. One Lac Seventy One Thousand Sixty Only) Vide UTR No. UBIN)21235647983, Dated 18/08/2025.

19) The owner/occupier shall deposit 1% of Fire Prevention fees every year to this department (as per Maharashtra Fire Prevention and life safety measures act 2006 & Amendment Act-2023 section- 13).

20) Valid Upto: 24/08/2027.

Fire Officer
Fire & Emergeney Services
Nagar Panchayat, Parseoni.

PRESIDENT
SANDEEP SHIKSHAN SANSTHA
NAGPUR

PRINCIPAL
SAROJANI PUBLIC SCHOOL
PARSEONI